

WESTERN RESOURCE ADEQUACY PROGRAM

PUBLIC WEBINAR

JANUARY 26, 2022 1-2:30 PM PT



AGENDA

- » WRAP Update
- » Load Forecasting
- » Solar Accreditation
- » Wind Accreditation
- » Wrap up

WRAP UPDATE

- » Published Governance version 4 on Jan 13th
 - Extensive process with states facilitated by WIEB*
 - Incorporated feedback from 2B Detailed Design*
 - Webinar on Governance scheduled for Friday Feb 4th 12-3pm PT*
- » On track to file with FERC in Spring
- » Standing up Program Review Committee and Nominating Committee
- » Task Forces working through outstanding design topics from Phase 2B

WRAP UPDATE

LOAD
FORECASTING

SOLAR
ACCREDITATION

WIND
ACCREDITATION

WRAP UP



Load Forecasting Methodology

Background

- » Critical that quantified elements are consistent and objective
- » In 2B: Load forecasting to be determined and submitted by each Participant, based on their own load forecasting methodology
- » Load forecasts are used:
 - *As inputs for the LOLE and ELCC studies*
 - *To establish the load term in the compliance metric*
- » Not a replacement for existing IRP or infrastructure planning processes



WRAP UPDATE

**LOAD
FORECASTING**

SOLAR
ACCREDITATION

WIND
ACCREDITATION

WRAP UP

LOAD FORECASTING

CURRENT STATE

- Task force considering approach for **non-binding seasons**
- Anticipate Program Review Committee will work on proposal for **binding seasons**

ELCC STUDY PROCESS

REVIEW (FROM 2B)

“Pure Capacity 1”

Calculate "pure capacity(+/-)" added to benchmark system to achieve 1-in-10 LOLE

- › The benchmark system is defined as load supplied by all conventional resources, storage hydro generation and VERS **excluding the VER of interest**

“Pure Capacity 2”

Calculate "pure capacity(+/-)" added full system (all resources included) to achieve 1-in-10 LOLE

ELCC of VER of interest = “Pure Capacity 1” – “Pure Capacity 2”

ZONAL ELCC APPROACH

REVIEW (FROM 2B)

- ELCC will be calculated on a zonal basis
- To ensure that over-accreditation of VERs does not occur, zonal ELCC will be scaled to RA footprint ELCC

A study of four wind zones reveals the following capacity values for wind in each zone:				
Zone 1	Zone 2	Zone 3	Zone 4	Total
1,000 MW	800 MW	700 MW	1,000 MW	3,500 MW
A study of the region reveals the following capacity value for the region's wind:				
Regional wind = 3,200 MW				
The zones will be recalculated as follows:				
Zone 1	Zone 2	Zone 3	Zone 4	Total
1,000 * (3,200/3,500)	800 * (3,200/3,500)	700 * (3,200/3,500)	1,000 * (3,200/3,500)	
914 MW	732 MW	640 MW	914 MW	3,200 MW

ADDITIONAL ELCC CONSIDERATIONS

- How to handle 'next-in' resource
 - › Study incremental additions of wind and solar resources in each zone (2,000, 4,000 and 6,000 MWs)
 - › PO provides an ELCC curve to determine future capacity values for new resources dependent upon the penetration of resources in that zone
- Appropriately accounting for scaling from:
 - Seasonal, footprint-wide ELCC by resource (to) ->
 - Seasonal, zonal ELCC by resource (to) ->
 - Monthly, zonal ELCC by resource ->

SOLAR ACCREDITATION

WRAP UPDATE


LOAD
FORECASTING

**SOLAR
ACCREDITATION**

WIND
ACCREDITATION

WRAP UP

- » Following proposal was presented to RA Participant Committee (RAPC) in early December
- » Robust discussion on the merits of two zones (North and South)
 - Trade-offs: modeling / computation time and resources that occur with a zone-heavy approach
 - East/West diversity considered



SOLAR ACCREDITATION PROPOSAL

The WRAP footprint will be split into two zones for the purposes of modeling Solar resources in the ELCC study

- Zone 1 – North
 - › *Washington, Oregon, Idaho, Montana, Wyoming*
- Zone 2 – South
 - › *California, Nevada, Utah, Arizona*
- Allocation of ELCC within each zone based on average monthly output on the capacity critical hours (CCHs) (real or synthesized output)
 - › *Anticipated to capture the time zone and geographic (East/West) diversity of resources*

$$\text{Resource ELCC} = \text{Monthly ELCC MW} * \frac{\text{Resource average hourly net power output on top 5\% of net load hours (CCH)}}{\text{Zone total average hourly net power output on top 5\% of net load hours (CCH)}}$$

Analysis of historical average hourly net power output will utilize the following data:

- 3 years of data, if available
 - › No less than 3 years will be utilized - if 3 years of data is not available, resource will receive class ELCC % * nameplate*
- Allocation of zonal ELCC to individual resource may be adjusted as actual production data is accumulated

*See exception for new / repowered resources

WRAP UPDATE

LOAD

FORECASTING

SOLAR

ACCREDITATION

WIND

ACCREDITATION

WRAP UP

Solar Degradation

- » Degradation approximation of 0.5% per year will be applied to the last year's historical performance

Example: In year 2021, PO would be modeling for 2023, using historical information from 2020

Anticipate a 1.5% degradation from the 2020 historical performance for 2023, 2% for 2024, etc.

New and Repowered Facilities

- » Participant (or resource owner) will be responsible for synthesizing a 3-year forecasted output, using:

Manufacturer's engineering or performance data

Actual weather (preferably from on-site, but not from outside of 50-mile radius) and/or

Historical performance of similar resources within a 50-mile radius

- » As actual data is accrued, it will replace synthesized data as available



WIND ACCREDITATION

Background

- » Mapped wind installations by county – provided insight into how footprint’s wind is clustered
- » Compared publicly available wind data for various regions to evaluate appropriateness of a grouping based on average weather conditions
- » Decision was made to prioritize grouping by wind penetration in a geographic area
- » Initial zones not intended to be static for the remainder of the program – ELCC modeling is completed each year; wind concentration will be re-evaluated for appropriateness

WRAP UPDATE

LOAD

FORECASTING

SOLAR

ACCREDITATION


WIND

ACCREDITATION



WRAP UP



WRAP - Counties with Installed Wind



WRAP - Counties with Installed Wind



WRAP UPDATE

LOAD
FORECASTING

SOLAR
ACCREDITATION

**WIND
ACCREDITATION**

WRAP UP

Recommended Wind Zones:

1. Columbia Gorge (Southern Washington / Northern Oregon)
2. All 'other' US installed wind (everything but Columbia Gorge, Montana, Wyoming)
3. Montana
4. Wyoming
5. British Columbia

$$\text{Resource ELCC} = \text{Monthly ELCC MW} * \frac{\text{Resource average hourly net power output on top 5\% of net load hours (CCH)}}{\text{Zone total average hourly net power output on top 5\% of net load hours (CCH)}}$$

Analysis of historical average hourly net power output will utilize the following data:

- 3 years of data, if available
 - No less than 3 years will be utilized - if 3 years of data is not available, resource will receive class ELCC % * nameplate*
- Allocation of zonal ELCC to individual resource may be adjusted as actual production data is accumulated

*See exception for new / repowered resources

WRAP UPDATE

LOAD
FORECASTING

SOLAR
ACCREDITATION

WIND
ACCREDITATION

WRAP UP

New and Repowered Facilities

- » Participant (or resource owner) will be responsible for synthesizing a 3-year forecasted output, using:

Manufacturer's engineering or performance data

Actual weather (preferably from on-site, but not from outside of 50-mile radius) and/or

Historical performance of similar resources within a 50-mile radius

- » As actual data is accrued, it will replace synthesized data as available



WRAP UPDATE

LOAD

FORECASTING

SOLAR

ACCREDITATION

WIND

ACCREDITATION

WRAP UP

WRAP UP

- » Upcoming webinars to discuss design updates as they're approved by RAPC
- » Governance webinar Friday Feb 4th 12-3pm PT

Register for the governance webinar here: <https://www.nwpp.org/events/118>



THANK YOU

CONTACT US AT WRAP@NWPP.ORG

