



Western Resource Adequacy Program

PRC WP 26-27 Task Force 14/19 – DC-LL Meeting#4

September 22nd, 2026; 10-12am PPT

Meeting Objectives

1. Approve Task Force [Charter](#)
2. Explore WRAP touch points for large loads
3. Discuss policy around new load additions with associated demand response
4. Continued discussion of Scope Proposal

Meeting Agenda

1. Task Force Governance
 - Approve [Charter](#)
 - Charter was approved as presented.
2. WRAP Timeline and Large Loads with Own Generation
 - WPP reviewed how large loads and associated resources move through the WRAP timeline, including the Advance Assessment, P50 Peak Load Forecast, Forward Showing, and Operations Program.
 - Participants can incorporate known discrete load additions (or subtractions) into their P50 Peak Load Forecast, which ultimately increases (or decreases) the FS Capacity Requirement.
 - Discussion focused on how on-site/backup generation interacts with WRAP, particularly when generation is used to offset load (demand response) rather than registered as a WRAP resource.
3. P50 Peak Load Forecast Additions
 - Discussed scenarios where a new data center load is included in the P50 Peak Load Forecast, but there is insufficient time to conduct the required Demand Response Capability Testing (due to generator substitution).
 - WPP reviewed existing provisions for new resources that cannot complete Capability Testing prior to Forward Showing, including an initial reduced QCC value with testing expected before the following season.
 - Discussion focused on whether that existing framework appropriately addresses new large-load/DR situations or whether additional policy flexibility is needed.
4. Proposal Scoping – Continued
 - Task Force continued narrowing the issues that should be addressed through a policy proposal versus topics that may be better handled through guidance or continued stakeholder education.
 - Discussion continued around:
 - Treatment of on-site/backup generation and its relationship to Demand Response.
 - Appropriate visibility and accounting when on-site generation offsets large load.
 - Ensuring any Demand Response Capacity Resource used in the Forward Showing appropriately carries into the Operations Program.
 - WPP noted the discussion provided useful direction and “sideboards” for beginning to develop a proposal.
 - Members also supported continued dialogue between large-load customers and WRAP Participants as both groups work through how these arrangements interact with the program.
5. Next Steps
 - WPP will use Task Force feedback to begin further developing the scope and potential policy direction.
 - Next meeting: October 6, 2026.

WPP forums will not foster or allow communications or practices that violate antitrust laws. Please avoid discussion of topics that would result in anti-competitive behavior, including but not limited to: availability of or terms of services and sales, design of products, price setting, or any other activity that might unreasonably restrain competition.