

Seattle City & Light Comment

“The WestTEC study plan should monitor lower voltage BPS transmission lines where historically there have been contingencies that impacted 200 kV and above facilities due to parallel flows.”

Uzma Siddiqi, Seattle City & Light